



OFFICE OF THE FIRE OFFICER,
BHAWANIPATNA CIRCLE, BHAWANIPATNA

Letter No. 627 / BWP CrI

Dtd. 08.10.2022

To,

The principal,
MKM Center of Education
Baldiamal, Junagarh, Kalahandi

Ref :- Online Fire Safety Application No. FSC1409290042022000074.

Sub:- Issuance of Fire Safety Certificate in respect of G+1 Storied Residential Building, MKM Center of Education.

Madam,

With reference to the subject cited above this is intimate that as per rule 3(j) Of Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019, the following Education Building are only required to obtain Fire Safety Certificate.

1. Having height of 12 mtr.and above or,
2. Having a built-up area of 1000 square meters or above, or
3. Having 03 storied buildings.

However, under taken verification by a team of fire service officer on 02.10.2023, MKM Center of Education is suitable over Baldiamal, Junagarh, Kalahandi , Odisha ,contains 01 block having G+1 floors, total built-up area = approx.1200.99 Sq. mt and height- approx.7 mtr.


Hence, as per provision of rule 3(j) of Odisha prevention and fire safety (Amendment) Rules, 2019, fire safety certificate (F.S.C) is not required to the afore-said educational building as on date of verification i.e 02.10.2023.

However, 06 nos of ABC (6kgs), Fire Extinguisher, has been installed which was found working condition during verification.

This Certificate is valid for 2 years (07.10.2024)

Here with your application is disposed of accordingly.

Yours Faithfully


08/10/22
Deputy Fire Officer
Bhawanipatna Circle, Bhawanipatna
Dy. Fire Officer
Bhawanipatna Circle, Bhawanipatna